



June 4, 2015

Josh Hanlon
Regional Director of Growth Operations
Liquid Environmental Solutions
527 Pleasant St
Attleboro, MA 02703

Ref: Clean and Decontaminate 10,000 Gallon AST.

Dear Mr. Hanlon,

Below please find a description of the work Cyn Environmental provided to your company Liquid Environmental Solutions cleaning a 10,000-gallon Above Ground Storage Tank contaminated with TSCA regulated Pcb oil/water and TSCA regulated Pcb sludge. Due to the unforeseen sludge contamination this project was completed over a 2-week time span. The summary is as follows:

- 4/29/2015 Cyn provided a three-man crew to pump 2830 gallons of Pcb contaminated Oil/Water from the storage tank in question. The breakdown of the load was as follows: 1980 gallons of water, 850 gallons of oil. The load was transported on a Cyn licensed vehicle (Manifest #014684504JJK) to Cyn's EPA TSCA licensed Dover, NH facility (EPA # NHD082303777). The waste was disposed of in compliance with TSCA regulations 40 C.F.R 761.60
- 5/14/2015 Cyn returned to remove Solid/Sludge contamination from said tank. Cyn provided a three man crew to vector 16,654 pounds of Pcb contaminated Solids/Sludge from the tank. The tank was then power washed, rinsed and cleaned with virgin #2 fuel and Penatone soap. The load was transported on a Cyn licensed vehicle (Manifest #014684993JJK) to Cyn's EPA TSCA licensed Dover, NH facility (EPA # NHD082303777). The waste was disposed of in compliance with TSCA regulations 40 C.F.R 761.60. The Sludge component of the waste is being shipped to Clean Harbors for incineration. The solid component will be shipped to Wayne Disposal in Bellville MI for landfill.
- 6/4/2015 Cyn returned with a Chemist and Foreman to obtain 6/100cm² wipe samples from the decontaminated tank. All 6 samples were analyzed and had a

range of 1.0ug/100cm² and 4.4ug/100cm² all below the required <10ug/100cm².
(See Attached Analytical) Based on CFR 761.79 (Wipe samples from

- Non-porous surfaces) the tank in question can be put into service without any restrictions.

Should you have any questions or concerns about the above work, please feel free to contact me at your earliest convenience.

Best Regards,



Mark Theriault
Regulatory Compliance Manager
Laboratory Manager
P 781.341.5108 X220
F 781.341.3318
C 508.415.1025
mark_theriault@cynenv.com

Cyn Environmental Services
1771 Washington St
Stoughton, MA 02072
www.cynenv.com